

Annex to LegCo Question No. 9

Data on bacteriological quality, mercury and other chemicals in the raw water at Muk Wu Pumping Station, before and after the commissioning of the Dongjiang –Shenzhen closed aqueduct :

	Total Coliforms	E. coli	Mercury	Ammonical nitrogen	Total Phosphorus (as P)
Unit	no./l	no./l	mg/l	mg/l	mg/l
1/1/2003 to 31/5/2003	4,550	2,130	<0.00005	0.81	0.2
1/7/2003 to 31/3/2004	2,830	1,080	<0.00005	0.14	0.09
GB3838-88 Type II Standard	No standard set	No standard set	=< 0.00005	No standard set	=< 0.1